



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Report Number: 21-12-01039  
Received Date: 12/08/2021  
Reported Date: 12/15/2021  
Sampled By: Charles Hollmuller  
Tech Certification #: LBP-I-I213156-1

Project/Test Address: 210257; Asbury Schools Maintenance Facility; Asbury Park, NJ 07712

Client Number:  
201327

# Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-12-01039-001	MBATH SF1AP	12/04/2021	MAINTENANCE BUILDING BATH SINK	<1.00	12/14/2021	
21-12-01039-002	MSLOPS SF2AP	12/04/2021	MAINTENANCE BUILDING SLOP SINK	35.8	12/14/2021	
21-12-01039-003	MAKIT SF3AP	12/04/2021	MAINTENANCE BUILDING KITCHEN SINK	<1.00	12/14/2021	

Method: EPA 200.8  
Analyst: Ailea Cabatbat  
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

*Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion