



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Report Number: 21-12-01032

Received Date: 12/08/2021  
Reported Date: 12/15/2021  
Sampled By: Charles Hollmuller  
Tech Certification #: LBP-I-I213156-1

Project/Test Address: 210257; Asbury Middle School; 1200 Bangs Ave; Asbury Park, NJ 07712

Client Number:  
201327

# Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-12-01032-001	MS-KITS-AP	12/04/2021	KITCHEN SINK SOUTH	1.28	12/13/2021	
21-12-01032-002	MS-KITNE-AP	12/04/2021	KITCHEN SINK NORTH EAST	<1.00	12/13/2021	
21-12-01032-003	MS-KITNW-AP	12/04/2021	KITCHEN SINK NORTH WEST	3.32	12/13/2021	
21-12-01032-004	MS-KITKETE	12/04/2021	KITCHEN POT FILLER KETTLE	123	12/13/2021	
21-12-01032-005	MS-1IM-AP	12/04/2021	ICE MACHINE KITCHEN	<1.00	12/13/2021	
21-12-01032-006	MS-1B5-AP	12/04/2021	REAR GYM FOUNTAIN 1	<1.00	12/13/2021	
21-12-01032-007	MS-1B6-AP	12/04/2021	REAR GYM FOUNTAIN 2	<1.00	12/13/2021	
21-12-01032-008	MS-1FCUSAP	12/04/2021	CUSTODIAL OFFICE	27.5	12/13/2021	
21-12-01032-009	MS-1B7-AP	12/04/2021	FOUNTAIN OUTSIDE RM 123	9.43	12/13/2021	
21-12-01032-010	MS-1FWR-AP	12/04/2021	OFFICE WOMENS BATHROOM SINK	1.94	12/13/2021	
21-12-01032-011	MS-1-NUR	12/04/2021	NURSES OFFICE SINK	<1.00	12/13/2021	
21-12-01032-012	MS2-B12-AP	12/04/2021	WEST END HALL FOUNTAIN	7.33	12/13/2021	
21-12-01032-013	MS-2B14-AP	12/04/2021	EAST HALL FOUNTAIN	<1.00	12/13/2021	

# Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 21-12-01032

Project/Test Address: 210257; Asbury Middle School; 1200 Bangs Ave; Asbury Park, NJ 07712

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-12-01032-014	MS-2B20-AP	12/04/2021	FOUNTAIN ROOM 404	<1.00	12/13/2021	
21-12-01032-015	STD1-EW-CAP	12/04/2021	EAST LOCKER ROOM	72.1	12/15/2021	
21-12-01032-016	STD2-CW-AP	12/04/2021	CENTER ROOM WATER FOUNTAIN	71.8	12/15/2021	
21-12-01032-017	STD3-WWC-AP	12/04/2021	WEST LOCKER ROOM	39.5	12/13/2021	
21-12-01032-018	STD IM AD	12/04/2021	ICE MACHINE	<1.00	12/13/2021	
21-12-01032-019	STDS F1AP	12/04/2021	SLOP SINK	5.20	12/15/2021	
21-12-01032-020	STDSIM12	12/04/2021	ICE MACHINE OFFICE	<1.00	12/13/2021	

Method: EPA 200.8  
Analyst: Ailea Cabatbat  
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

*Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L = micrograms per liter ppb = parts per billion



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Report Number: 22-05-04372

Received Date: 05/23/2022  
Reported Date: 05/27/2022  
Sampled By: Andrew Wong  
Tech Certification #:

Project/Test Address: 220430; Martin Luther King Middle School; 1200 Bangs Avenue; Ashbury Park, NJ

Client Number:  
201327

# Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04372-001	MS-132-WC-AP	05/21/2022	ROOM 132 WATER COOLER	<1.00	05/26/2022	
22-05-04372-002	MS-1B2-AP	05/21/2022	CAFE HALLWAY BUBBLER	<1.00	05/26/2022	
22-05-04372-003	MS-1B3-AP	05/21/2022	GYM HALL BUBBLER 1	13.7	05/26/2022	
22-05-04372-004	MS-1B4-AP	05/21/2022	GYM HALL BUBBLER 2	18.1	05/26/2022	
22-05-04372-005	MS-1B8-AP	05/21/2022	BUBBLER 1 OUTSIDE ROOM 115	4.42	05/26/2022	
22-05-04372-006	MS-1B9-AP	05/21/2022	BUBBLER 2 OUTSIDE ROOM 115	2.50	05/26/2022	
22-05-04372-007	MS-1B10-AP	05/21/2022	BUBBLER 1 OUTSIDE ROOM 105	<1.00	05/26/2022	
22-05-04372-008	MS-1B11-AP	05/21/2022	BUBBLER 2 OUTSIDE ROOM 105	1.76	05/26/2022	
22-05-04372-009	MS-2B13-AP	05/21/2022	2ND FLOOR MID HALL BUBBLER	1.74	05/26/2022	
22-05-04372-010	MS-2B14-AP	05/21/2022	2ND FLOOR EAST HALL BUBBLER 1	1.60	05/26/2022	
22-05-04372-011	MS-2B15-AP	05/21/2022	2ND FLOOR EAST HALL BUBBLER 2	<1.00	05/26/2022	
22-05-04372-012	MS-3B16-AP	05/21/2022	3RD FLOOR WEST HALL BUBBLER	21.1	05/26/2022	

# Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 22-05-04372

Project/Test Address: 220430; Martin Luther King Middle School; 1200 Bangs Avenue; Ashbury Park, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04372-013	MS-3B17-AP	05/21/2022	3RD FLOOR MID HALL BUBBLER	<1.00	05/26/2022	
22-05-04372-014	MS-3B18-AP	05/21/2022	3RD FLOOR EAST HALL BUBBLER 1	4.34	05/26/2022	
22-05-04372-015	MS-3B19-AP	05/21/2022	3RD FLOOR EAST HALL BUBBLER 2	7.83	05/26/2022	
22-05-04372-016	MS-3BSS-AP	05/21/2022	SUNROOM SINK	<1.00	05/26/2022	

Method: EPA 200.8

Analyst: Allison Rodriguez

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:



Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion